



IJEAST

INTERNATIONAL JOURNAL
OF ENGINEERING APPLIED SCIENCE
AND TECHNOLOGY



VOLUME : 6 ISSUE : 3 Print / Issue Publication Date: 16-Sep-2021



ISSN : 2455-2143



DOI : 10.33564/IJEAST.2021.v06i03.019

Indexed In



WWW.IJEAST.COM

editor@ijeast.com

HIGHLY SENSITIVE DETECTION OF LEAD IONS IN WATER USING ETCHED FBG

V.K.Kulkarni¹, A.S.Lalasangi², S.B.Patil³, S. R. Mannopantar⁴, M. S. Jadhav⁵ & U.S.Raikar⁶

¹Department Of Physics, Angadi Institute Of Technology & Management, Belagavi, (Karnataka), India.

² Department Of Physics, Smt. I. S. Yadav Government First Grade College Ramdurg, (Karnataka), India

³Department Of Physics, Government First Grade College, Ranebennur (Karnataka) India.

⁴ Department Of Physics, Government First Grade College, Harihar, (Karnataka) India

⁵Department Of Physics, J. S. S. Arts, Science And Commerce College, Gokak (Karnataka) India.

⁶Department Of Physics, Karnatak University, Dharwad (Karnataka) India.

Abstract - Lead is a soft, ductile, malleable and naturally present in earth's crust. Lead is highly toxic element affects living organism even at lower concentration. Lead is used in many industries and its disposable is very difficult. Therefore, it may lead to various environmental hazardous problems. World Health Organization (WHO) and other organisation specify the presence of lead in drinking water not greater than 20 ppb. In the present work, a simple, affordable and precise way to detect the concentration of lead in water using Fibre Bragg gratings (FBG) is presented. FBG are formed using Phase mask technique and the cladding part over the grating region is etched with 40% Hydrofluoric acid (HF) solution. The sensor so developed is sensitive enough to find the presence of lead in water in the range 5-25 ppb.

Keywords: Fibre Bragg grating, Etching, Lead, sensor, ppb.

I. INTRODUCTION

Lead poisoning seems to be one of the major causes for critical health concern across world. It has been treated as one of the most harmful metal concern with public health environment[1,2]. Pollution caused due to heavy metals like mercury, arsenic, lead, copper, fluoride, zinc, chromium and many more which leads to major health issues in humans and animals[3,4]. It enters in the living system through ingestion of contamination in water and food materials[5-9]. As lead is not present in drinking water unless it is being contaminated during the transportation through metal pipes, PVC pipes and even through corrosion of plumbing material and solder, which may contain lead. The quantity of lead in water may even depends on the ages of pipes, duration of

water present in such pipes, minerals present in water, temperature and pH level of water[10,11].

Techniques reported various measurements in connection with identifying the presence of lead in water. The most common method is utilising the atomic absorption spectrometry technique and with this method most accurate measurement can be recorded[12,13]. The other methods reported are through Fluorescent technique and using optical fibres [5,14,15].

II. THEORY AND WORKING PRINCIPLE OF FBG SENSOR

Bragg gratings have great potential to operate in wavelength of 1350/1550 nm in optical communication system and such gratings are fabricated by exposing them to UV source. FBG are a sort of periodic variation in refractive index of core in a single mode photosensitive optical fibre [16].




Fig.1. The transmitted / reflected spectra of fiber grating.

The grating fabrication is carried out by the phase mask technique[7]. When a broad band source is connected to the one end of the FBG, we observe a narrow band of spectrum is reflected

back which is shown in **Fig.1**. This reflected spectra seems to very sensitive towards external perturbation [17,18]. Such FBG sensors are highly sensitive lower concentration mainly ppb level in liquid detection. This FBG is used as a chemical sensor to find out the contaminants in drinking water.

The present FBG is designed for chemical sensing. The cladding section of the grating region is to be etched, so that core modes interaction takes place directly with the surrounding environment directly[6,13,14]. This enhances the matching of effective refractive index of waveguide mode with surrounding region. When such etched region of grating is immersed in external liquid, leads to shift in Bragg wavelength ($\delta\lambda_B$) given by the following relation[7].

$$\delta\lambda_B = 2\Lambda\delta n\delta\eta_p \quad (1)$$

Where, Λ is grating period, n corresponds to variation of refractive index of cladding and surrounding region and $\delta\eta_p$ corresponds to change in fraction of unperturbed mode power, which enters in to the etched region.

III. EXPERIMENTAL PROCEDURE

The grating region is to be etched in such a way that complete cladding region has to be taken out. Initially broad band source is launched through 3 dB coupler in to the FBG and optical spectrum analyser (OSA). The wet chemical etching of the fiber cladding is carried out using 40 % HF placed in a Teflon container. The etching process is very closely monitored through the OSA. Around 55 minutes, a sudden shift in wavelength was observed and grating region was removed from HF solution. This clearly indicates the etching of cladding region completely. This etched grating region is now washed with distilled water and followed by isopropyl alcohol solution. Now this etched FBG is set ready for further experimental procedure. **Fig.2**. shows the variation of spectra before after etching process.




Fig.2. Etching process with FBG

Etching of FBG at sensing region has been carried out in order to make more sensitive for surrounding environment. In present report, designed etched FBG is used to detect and determine the lead contaminant in water at ppb level.

The test solution for the Lead is prepared by dissolving Lead nitrate salt in distilled water. The stock solution is prepared and concentration varying from 5 ppb to 25 ppb is prepared by further diluting the stock solution. For each 10 ml of test solution 0.4 ml reagents namely Ethanol, Ammonia, Pottassium Cyanide, hydroxylammonium chloride and Dithizone are added in a sequence mentioned. Now this test solution is mixed thoroughly. In the presence of Pottassium Cyanide, lead (II) ions interacts with Dithizone to form lead Dithizonate to form a pink colour solution.

The experimental setup to detect lead ions in water at room temperature is shown in **Fig.3**. The Broad Band Source of 17 mW (JDS-UNIPHASE) of wavelength 1530-1600 nm is launched through 3 dB coupler (2 x2) in to the FBG. One of its output ends is connected to the FBG and the other end is free. The FBG is immersed in test solution containing different concentration of lead solution. The reflected spectrum is observed through Optical Spectrum Analyzer (OSA) [ANRITSU] connected through one of the free input end of 3 dB coupler.




Fig.3. Experimental setup for the detection of lead in water

Standard test solutions of lead varying from 5 ppb to 25 ppb are kept ready for experimental work. Initially it is recorded with lower concentration of 5 ppb and this test solution is transferred in to groove made-up Teflon container in which the etched grating portion is placed. When broad band source is launched in to FBG through 3 dB coupler, the reflected spectra from FBG is recorded through OSA. Further the process is continued for other higher concentration of lead in an increasing

order. During each reading the Teflon container is cleaned thoroughly with isopropyl alcohol and distilled water to avoid contamination. When test solution is placed in Teflon container the effective refractive index of FBG core mode changes, and leads to shift in Bragg wavelength (λ_B). It shows that as the concentration of the solution varies there is a change in Bragg wavelength.

IV. RESULTS AND DISCUSSION

The detection of lead in water using FBG is carried out at room temperature. The readings were taken from lower concentration of 5 ppb to 25 ppb and corresponding changes of wavelength, intensity and concentration were tabulated. Firstly the variation of intensity with concentration of lead is shown in Fig 4 (a) & (b).




Fig.4. (a) intensity Vs wavelength spectrum (b) Normalized spectrum for various concentrations of samples.

It is clearly evident from the graph that as lead concentration goes on increasing the intensity and wavelength shifts are clearly distinguishable. When intensity versus wavelength variation is plotted the variation of 2.4617 dBm/nm is observed as shown in Fig.5.




Fig.5. Linear fit of intensity Vs Wavelength for lead detection

The variation of wavelength against concentration of lead is shown in Fig.6. and the high sensitivity was observed of 0.00276 nm/ppb. As FBG based sensor is wavelength dependent and is quite sensitive one. Thus, the sensor shows a very high sensitivity in detection of presence of lead in water using FBG.




Fig.6. Linear fit of wavelength Vs concentration for lead detection

Similarly the graph of Intensity versus concentration was plotted as shown in Fig. 7 and the sensitivity is 6.7841 dBm/ppb. Thus our sensor so developed is sensitive enough in detecting the presence of lead in water within the permissible standard level given by various authorities[19].




Fig.7. Linear fit of intensity Vs concentration for lead detection

It reveals that as increase in the sample concentration Bragg shift occurs with increase in intensity of the signals and sensitivity 6.7841 dBm/ppb at lower concentration. It confirms that designed sensor is highly sensitive at lower concentration in detecting the chemical species.

V. CONCLUSION

The variation shift in Bragg wavelength is observed as the concentration goes on increasing. It shows a red shift in wavelength as the intensity decreases. The high sensitivity observed is 0.00276 nm/ppb. The above all results reveal that the FBG chemical sensor is one of the sensitive and desirable components in detection of lead in water. In FBG Bragg wavelength is the characteristic parameter involved in building such sensors. The measurement techniques are not affected with perturbations such as variation in input power and thus capable enough in absolute measurement of the measurand. The detection limits are far better than other methods reported. Thus FBG chemical sensor proves to be a potential tool in measuring the heavy metal like lead (II) present in water. Our detection level is very high within the range of limitations set by WHO and other agencies. The sensor so developed is quite affordable, simple in design and reproducible.

VI. ACKNOWLEDGMENT

The present work is supported by the VGST Karnataka Science and Technology Promotion Society (KSTePS) Department of IT, BT and S&T Government of Karnataka, Bengalooru., INDIA.

VII. REFERENCES

[1] S. S. Chong, A. R. A. Aziz, and S. W.

Harun, Fibre Optic Sensors for Selected Wastewater Characteristics,13(7), 2013, pp. 8640–8668.

[2] L. Wong, R. Deo, S. Rathnayaka, B. Shannon, and C. Zhang, Leak Detection in Water Pipes Using Submersible Optical Optic-Based Pressure Sensor, 18(12), 2018, pp. 4192 (1–17) .

[3] T. M. Libish *et al.*,Optik Detection and analysis of paraffin oil adulteration in coconut oil using fiber optic long period grating sensor, *Optik - International Journal for Light and Electron Optics*, 122 (21), 2011, pp. 1939–1942,

[4] U. S. Raikar *et al.*, Chemical Cd concentration sensor based on fiber grating technology, *Sensors & Actuators: B. Chemical*, 161(1), 2012, pp. 818–823,.

[5] A. M. Valadez, C. A. Lana, S. I. Tu, M. T. Morgan, and A. K. Bhunia, “Evanescent wave fiber optic biosensor for Salmonella detection in food,” *Sensors*, 9, 2009, pp. 5810–5824.

[6] L. S. Laxmeshwar, M. S. Jadhav, J. F. Akki, P. Raikar, and U. S. Raikar,Elemental analysis of wastewater effluent using highly sensitive fiber Bragg grating sensor, *Optics and Laser Technology*, 105, 2018,pp. 45–51.

[7] L. S. Laxmeshwar *et al.*, “Highly sensitive fiber grating chemical sensors: An effective alternative to atomic absorption spectroscopy,” *Optics & Laser Technology*, 91, 2017,pp. 27–31.

[8] L. S. Laxmeshwar *et al.*, Chemical Quantification of chloride and iron in sugar factory effluent using long period fiber grating chemical sensor, *Sensors & Actuators: B. Chemical*, vol. 258, 2018, pp. 850–856.

[9] M. S. Jadhav, L. S. Laxmeshwar, J. F. Akki, P. U. Raikar, and J. Kumar, “Optical Fiber Technology Fluoride contamination sensor based on optical fi ber grating technology,” *Optical Fiber Technology*, vol. 38, no. September, 2017, pp. 136–141.

[10] A review of permissible limits of drinking water *M Kumar and A. Puri*, A review of permissible limits of drinking water, *Indian J Occup Environ Med.* 16(1),2012,pp. 40–44.

[11] M. J.Brown and S.Margolis, Lead in Drinking Water and Human Blood Lead Levels in the United States. Supplements. CDC (Morbidity and Mortality Weekly Report MMWR) 61(04),2012, 1-9..



- [12] Jyoti F. Akki, Anandkumar S. Lalasangi, Prasad U. Raikar, T. Srinivas, Lata S. Laxmeshwar, and U. S. Raikar, Core-cladding mode resonances of long period fiber grating in concentration sensor, *IOSR Journal of Applied Physics (IOSR-JAP)*, 4(3), 2013, pp. 41–46.
- [13] S. D. Richardson, Disinfection by-products and other emerging contaminants in drinking water, *TrAC - Trends in Analytical Chemistry*, 22(10), 2003, pp. 666–684.
- [14] C. A. Villarruel, D. D. Dominguez, and A. Dandridge, “Evanescent Wave Fiber Optic Chemical Sensor,” *Proceedings of SPIE*, 798, 1987, pp. 225–229.
- [15] Y. J. Rao, “Recent progress in applications of in-fibre Bragg grating sensors,” *Optics and Lasers in Engineering*, 31(4), 1999, pp. 297–324.
- [16] B. Lee, Review of the present status of optical fiber sensors, *Optical Fiber Technology*, 9(2), 2003, pp. 57–79.
- [17] M. Latino, R. Montanini, N. Donato, and G. Neri, Ethanol sensing properties of PMMA-coated fiber Bragg grating, *Procedia Engineering*, 47, 2012, pp. 1263–1266.
- [18] M. B. Rao, M. R. Bhat, K. V. Madhav, and S. Asokan, “Structural Health Monitoring (SHM) Using Strain Gauges , PVDF Film and Fiber Bragg Grating (FBG) Sensors : A Comparative Study,” 2006. <https://www.researchgate.net/publication/239821755>
- [19] J. Fawell and M. J. Nieuwenhuijsen, Contaminants in drinking water, DOI: 10.1093/bmb/ldg027

IJEAST

INTERNATIONAL JOURNAL OF ENGINEERING APPLIED SCIENCE AND TECHNOLOGY



AUTHORS

-  V.K.Kulkarni
-  A.S.Lalasangi
-  S.B.Patil
-  S. R. Mannopantar
-  M. S. Jadhav
-  U.S.Raikar



ABOUT IJEAST

International journal of Engineering Applied Science and Technology (IJEAST) is a peer-reviewed, open access journal that publishes high - quality research paper in the field of Engineering, Applied Science and Technology.

IJEAST aims to provide a platform for researchers, academicians, and professionals to share their innovative ideas, research findings, and practical experiences with the global scientific community.

JOURNAL METRICS

H

H-INDEX

33

i10

i10-INDEX

154

“

IJEAST
CITATIONS

9,647

(IJEAST CITATIONS)



PEER-REVIEWED
& OPEN ACCESS

PUBLISHED
MONTHLY



PEER REVIEWED

All submission are rigorously peer reviewed to ensure quality.



AUTHORS ARE OUR PRIORITY

We value our authors and recognize their contribution to the advancement of research and knowledge.



OPEN ACCESS

Free and unrestricted access to research for all.



GLOBAL REACH

Connecting researchers and professionals worldwide.



TIMELY PUBLICATION

We ensure a swift and efficient publication process.



For more information, visit our website
www.ijeast.com



editor@ijeast.com



www.ijeast.com



India



2455-2143